

## Access Control System Units

[See General Information for Access Control System Units](#)

### ROSSLARE ENTERPRISES LTD

FLAT 5, 9TH FL WING FAT IND BLDG  
12 WANG TAI RD  
KOWLOON BAY  
KOWLOON, HONG KONG

BP9264

### ANSI/UL 294 (7th ed.) Access Control Performance Levels

Model	Product Type	Access Control				Example Conditions and Notes
		Line Security	Destructive Attack	Endurance	Standby Power	
AC-825IP, AC-825IP-U	Control Unit	I	I	IV	II	—
D-805	Door Expansion Module	I	I	IV	II	—
P-805	PLC I/O Expansion module	I	I	IV	II	—
R-805	Relay Output Expansion Module	I	I	IV	II	—
S-805	Supervised Input Expansion module	I	I	IV	II	—
ME-1515, ME-1515-U	Enclosure (includes UL Listed power supply, power management board and tamper assembly)	I	I	IV	II	—
AC-225U, AC-225IPU, AC-215-BU, AC-215IP-BU, AC-225-BU, AC-225IP-BU	Control Unit	I	I	IV	II	—
AC-225, AC-225IP, AC-215-DIN, AC-215IP-DIN, AC-225-DIN, AC-225IP-DIN	Control Board	I	I	IV	II(*)	(*) Note, provided by ME-1015-U
AC-825IP-PCBA	Control Board	I	I	IV	II(*)	(*) Note, provided by ME-1515 or ME-1515-U

PS-33, PM-10	Power Management Board	I	I	IV	II	—
ME-1015-U	Enclosure	—	1	—	II	—
MD-D02, MD-IO84	Expansion Module	I	I	IV	II(*)	(*) Note, provided by ME-1515 or ME-1515-U
MD-D02B, MD-IO84B	Expansion Module	I	I	IV	II(*)	(*) Note, provided by ME-1015-U

## ANSI/UL 294 (7th ed.) Access Control Performance Levels

Model	Product Type	Access Control				Standby Power	Example Conditions and Notes
		Line Security	Destructive Attack	Endurance			
AYC-Q64B	Accessory - Access Control Keypad/Reader	I	I	IV	I	—	
AYC-Q60	Access Controller/Keypad/Reader	I	I	IV	I	—	
EX-06, EX-16, EX-07, EX-17	Accessory - Request-to-Exit Switch	I	I	IV	I	Suitable for indoor or outdoor use	
OP10*, OP30*, OP40*, OP45*, OP90*, OP95*, AY-L12C, AY-M12C, AY-K12C, AY-H12C, AY-Q12C,	Access Reader	I	I	IV	I		

Access control unit suitable for indoor use only.

All readers suitable for indoor and outdoor use.

\* - Complimentary Listed under UEHX7.

Trademark and/or Tradename: "ROSSLARE".

Last Updated on 2021-02-11

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."