

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130801-BP9264  
**Report Reference** BP9264-20080725  
**Issue Date** 2013-AUGUST-01

**Issued to:** ROSSLARE ENTERPRISES LTD  
FLAT 12, 9TH FL WING FAT IND BLDG  
12 WANG TAI RD  
KOWLOON BAY  
KOWLOON HONG KONG

**This is to certify that  
representative samples of**

ACCESS CONTROL SYSTEM UNITS; SIGNAL  
APPLIANCES, MISCELLANEOUS CERTIFIED FOR  
CANADA

Security and General Signaling Equipment: Models:  
Access Control System , Model PS-C25TU Dual Relay  
Secured Power Supply unit controller.


Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 294 - Standard For Access Control System Units  
CSA C22.2 NO. 205 - Signal Equipment

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

